

833 Deep Creek Road



Sep 13, 2023 at 11:18:55 AM
Dereke D Planter Jr
Code Enforcement Supervisor



Sep 13, 2023 at 11:18:58 AM
Dereke D Planter Jr
Code Enforcement Supervisor

(All exterior finish shall be weathertight without excessive holes, cracks or rotted boards which permit air or water to penetrate rooms; Step Supports shall not be rotting, sagging or deteriorating.)

833 Deep Creek Road



Sep 13, 2023 at 11:19:13 AM
Dereke D Planter Jr
Code Enforcement Supervisor



Sep 13, 2023 at 11:19:55 AM
Dereke D Planter Jr
Code Enforcement Supervisor

(All exterior finish shall be weathertight without excessive holes, cracks or rotted boards which permit air or water to penetrate rooms; Windows shall be reasonably weathertight with no broken glass)

833 Deep Creek Road



(All exterior finish shall be weathertight without excessive holes, cracks or rotted boards which permit air or water to penetrate rooms; Floors broken, overloaded, decayed or excessively sagging sills, beams, girders and joists shall be prohibited)