

355 Dick Street



Feb 11, 2026 at 11:22:54 AM
Dereke D Planter Jr
Code Enforcement Supervisor



Feb 11, 2026 at 11:23:01 AM
Dereke D Planter Jr
Code Enforcement Supervisor

(No piers shall be used for support in which plumbline from top center falls outside middle one-third of base of pier; Adequate posts and railings, not rotted, broken or termite damaged, shall be provided.)

355 Dick Street



Feb 11, 2026 at 11:23:05 AM
Dereke D Planter Jr
Code Enforcement Supervisor



Feb 11, 2026 at 11:23:54 AM
Dereke D Planter Jr
Code Enforcement Supervisor

(Studs shall provide sufficient support for sheathing or exterior finish; All exterior finish shall be weathertight without excessive holes, cracks or rotted boards which permit air or water to penetrate rooms.)

355 Dick Street



Feb 11, 2026 at 11:23:56 AM
Dereke D Planter Jr
Code Enforcement Supervisor



Feb 11, 2026 at 11:24:08 AM
Dereke D Planter Jr
Code Enforcement Supervisor

(Excessive loose plaster, loose boards, or other loose wall materials shall be prohibited;
Studs shall provide sufficient support for the interior wall.)

355 Dick Street



Feb 11, 2026 at 11:24:45 AM
Dereke D Planter Jr
Code Enforcement Supervisor



Feb 11, 2026 at 11:23:17 AM
Dereke D Planter Jr
Code Enforcement Supervisor

(Roofing material, flashing and trim/fascia and walls. Proper flashing shall be provided at walls or chimneys.)

355 Dick Street



(All exterior finish shall be weathertight without excessive holes, cracks or rotted boards which permit air or water to penetrate rooms; roofing material, flashing and trim/fascia and walls; Studs shall provide sufficient support for the interior wall.)