

# 6545 Raeford Road



(Roof coverings to be be rotted, loose or sagging excessively. Structure was deem unsafe for interior firefighting operations.)




# 6545 Raeford Road



(Exterior walls not weathertight with excessive holes, cracks and rotted boards which permit air or water to penetrate rooms.)



# 6545 Raeford Road



(Roof covering loose, broken and missing flashing)

