

# 527 Orange Street



Sep 13, 2023 at 10:47:40 AM  
Dereke D Planter Jr  
Code Enforcement Supervisor



Sep 13, 2023 at 10:48:24 AM  
Dereke D Planter Jr  
Code Enforcement Supervisor

(Adequate posts and railings, not rotted, broken or termite damaged, shall be provided; Sheathing shall not be rotted, loose or sagging excessively; Roof covering shall not be loose, nor have holes or leaks)

# 527 Orange Street



Sep 13, 2023 at 10:48:42 AM  
Dereke D Planter Jr  
Code Enforcement Supervisor



Sep 13, 2023 at 10:49:25 AM  
Dereke D Planter Jr  
Code Enforcement Supervisor

(No rafters shall be rotted, broken, sagging excessively or having improperly supported ends; All exterior finish shall be weathertight without excessive holes, cracks or rottedboards which permit air or water to penetrate rooms)

# 527 Orange Street



(All exterior finish shall be weathertight without excessive holes, cracks or rotted boards which permit air or water to penetrate rooms)

# 527 Orange Street



Sep 13, 2023 at 10:51:05 AM  
Dereke D Planter Jr  
Code Enforcement Supervisor

(Dangerous or hazardous electrical conditions shall also be prohibited)