



Dec 13, 2021 at 1:06:17 PM  
Dereke D Planter Jr  
Code Enforcement Supervisor



Dec 13, 2021 at 1:06:32 PM  
Dereke D Planter Jr  
Code Enforcement Supervisor

(Roof and ceiling damaged due to fire; Interior finish has holes and excessive cracks which permit air to penetrate rooms)





Dec 13, 2021 at 1:06:52 PM  
Dereke D Planter Jr  
Code Enforcement Supervisor



Dec 13, 2021 at 1:06:58 PM  
Dereke D Planter Jr  
Code Enforcement Supervisor

(Flooring is rotten, worn and fire damaged, with holes or excessive cracks)





(flashing and trim/fascia damaged and burnt; roof rafters and sheathing need repair)